

Environmental Monitoring Report – Falconer Museum & Store

5th November 2025

21/08/ - 05/11/2025 data

*Note tiny tags calibrated October 2022


Handheld thermo-hygrometer weekly readings

individual tricimo rigis circos. In com y redumbo		
Museum Ground Floor (GF)	19.8°c	52.6%
Museum mezzanine	19.6°c	49.6%
Museum store GE	17 1°c	55.0%

Museum store GF	17.1°c	55.0%
Museum store 1 st Floor	16.5°c	56.3%

Data logger download data Museum


FalconerMuseum



Museum data

Museum	Temp °c	Relative Humidity %
Min	14.4°c	45.8%
Мах	22.7°c	60.6%
Average	20.0°c	52.0%

Museum_Sword cab



Museum Archaeological Cabinet	Temp °c	Relative Humidity %
Min	14.7°c	50.2%
Мах	22.2°c	54.8%
Average	19.0°c	53.0%

Museum Store GF






Museum Store GF	Temp °c	Relative Humidity %
Min	15.2°c	57.0%
Мах	19.2°c	67.1%
Average	17.0°c	63.0%

Museum Store 1st Floor

Museum Store_Stack 6



Museum Store 1 st – stack 6	Temp °c	Relative Humidity %
Min	14.1°c	54.4%
Max	20.2°c	68.8%
Average	17.0°c	58.0%

Museum store, traps 1 & 2 GF 2 silverfish, 1 moth

Museum store, trap 3 1st floor 1 brown moth

Museum, Falconer Room 1 wooly bear / carpet beetle larvae

Museum mezz telephone, trap 3 9 slaters

Nothing to be concerned about re-insects found on traps.

Richard Aitken ACR High Life Highland Conservation Service High Life Highland & Registration Centre.