## COMMERCIAL IN CONFIDENCE



**DE Operations North** Safeguarding Wind Energy

Kingston Road, Sutton Coldfield, B75 7RL

Chris Evans: Claire Duddy: Facsimile: Mobile:

0121 311 2025 0121 311 3714 0121 311 2218 07901 751770

E-mail: chris.evans@de.mod.uk claire.duddy@de.mod.uk E-mail: Internet Site: www.defence-estates.mod.uk



Mr Oliver Penney Seren Energy Ltd 1B High Street Clydach Swansea SA6 5LG

Your Reference:

Our Reference: DE/C/SUT/43/10/1/6830

Date:

5 September 2008

Dear Mr Penney

DE Ref Number: 6830

Site Name: Myreton Additional Turbines

I am writing to tell you that the MOD has no concerns with the proposal as set out in your pro-forma dated 15<sup>th</sup> August 2008.

The application is for 2 turbines at 74 metres to blade tip. This has been assessed using the grid references below as submitted in your pro-forma.

Turbine	100km Square	Esting	Northing
	Letter		
1	NJ	50160	56770
2	NJ	49950	56770

The MOD subject matter expert has identified a need for the turbines to be fitted with aviation lighting in the interests of air safety. All turbines should be fitted with a 200 candela omni-directional red light at the highest practicable point.

If the application is altered in any way we must be consulted again as even the slightest change could unacceptably affect us.

If you apply for planning permission you must ensure that the relevant planning authority consults this office to ensure that no concerns have arisen since the date of this letter.

If planning permission is granted you must tell us:

- the date construction starts and ends;
- the maximum height of construction equipment;
- the latitude and longitude of every turbine.







## **COMMERCIAL IN CONFIDENCE**

This information is vital as it will be plotted on flying charts to make sure that military aircraft avoid this area.

Yours sincerely



Chris Evans Assistant Safeguarding Officer – Wind Energy Defence Estates

SAFEGUARDING SOLUTIONS TO DEFENCE NEEDS





